

**ADDENDUM NO. 3**

**CITY OF HIALEAH  
36 UNIT ELDERLY HOUSING  
355 E. 32<sup>ND</sup> STREET  
HIALEAH, FLORIDA**

**JANUARY 11, 2013**

**TO ALL CONCERNED**

The original Contract Documents, for the Project entitled **CITY OF HIALEAH – 36 Unit Elderly Housing, FRAMING, INSULATION AND DRYWALL BID NO. 2012/13-3230-00-015** is hereby amended as noted in this **Addendum No. 3**.

This **Addendum No. 3** consists of 1 Typed Pages, 0 Sketches, 1 Attachments and 0 Drawings. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:  Date: January 11, 2013  
Luis Azan - Project Manager

**ACKNOWLEDGEMENT**

Receipt of this **Addendum No. 3** shall be acknowledged in the space provided on the ADDENDUM RECEIPT FORM (ARF) (copy attached) now a part of the Contract Documents faxed immediately to City of Hialeah @ (305) 687-2642, and submitted with sealed bids.

**IN THE CONTRACT DOCUMENTS:**

**CLARIFICATIONS:**

1. All recessed hi-hat channels must be of metal, not wood.
2. R-5 insulation on ALL outside walls must be rigid type not foil/paper.

**FRAMING, INSULATION AND DRYWALL BID - 2012/13-3230-00-015**

**PAGE 1 OF 1  
END OF ADDENDUM NO. 3**

**ADDENDUM RECEIPT FORM**

**CITY OF HIALEAH  
36 UNIT ELDERLY HOUSING  
355 E. 32<sup>ND</sup> STREET  
HIALEAH, FLORIDA**

**CONTRACTOR'S NAME** \_\_\_\_\_

**ADDRESS** \_\_\_\_\_

**PHONE NO.** \_\_\_\_\_ **FAX NO.** \_\_\_\_\_

**CONTACT NAME** \_\_\_\_\_ **SIGNATURE** \_\_\_\_\_

**THE BIDDER ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDUM BY SIGNING AND DATING BELOW: COPY OF THIS FORM MUST BE FAXED AND IMMEDIATELY TO CITY of HIALEAH @ (305) 687-2642.**

<u><b>ADDENDUM</b></u>	<u><b>SIGNATURE</b></u>	<u><b>DATE</b></u>
3		

**FRAMING, INSULATION AND DRYWALL BID - 2012/13-3230-00-015**

**ARF**